

SSO Notification List												
September 2010												
Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	9/3/2010	105 W. 39th Street	21210	Rags & Grease	Jones Falls	0:31	9:18 AM - 9:49 AM	Gray Water	155	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113067
2	9/5/2010	3404 St Paul Street	21218	Rags, Roots, & Grease	Inner Harbor	0:99	10:21 AM - 12:00 PM	Heavy Gray Water	297	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113111
3	9/5/2010	1820 Spence Street	21230	Rags, Roots, & Grease	Gwynns Falls	0:70	11:55 AM - 1:05 PM	Heavy Gray Water	210	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113112
4	9/7/2010	1200 Harwood Ave	21239	Roots	Herring Run	1:15	7:45 PM - 9:00 PM	Gray Colored Water	75	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113171
5	9/8/2010	2535 Lauretta Ave	21223	Rags	Gwynns Falls	0:55	11:40 AM - 12:35 PM	Sewer Water	110	Relieved M/L Choke with Pressure Jet	Line turned over to be CCTV'ed	113194
6	9/9/2010	3939 Falls Road	21211	Rags, Roots, & Grease	Jones Falls	2:00	7:52 AM - 9:52 AM	Heavy Gray Water	360	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113224
7	9/10/2010	2409 E Biddle Street	21213	Rags & Grease	Inner Harbor	4:40	9:20 AM - 2:00 PM	Gray Colored Water	Evidence of Overflow	Cleaned Line with Electric Cutting Machine	Line turned over to be CCTV'ed	113265
8	9/11/2010	5321 Frankford Ave	21206	Roots & Grease	Herring Run	1:15	9:45 AM - 11:00 AM	Gray Colored Water & Paper	1,125	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113288
9	9/11/2010	5423 O'Donnell Street	21224	Rags & Trash	Northwest Harbor	3:20	11:10 AM - 2:30 PM	Gray Colored Water	200	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113296
10	9/11/2010	5503 Peerless Ave	21207	Trash & Grease	Gwynns Falls	13:45	9/11/10 9:15 PM - 11:00 AM 9/12/10	Gray Colored Water	Evidence of Overflow	Cleaned Line with Electric Cutting Machine	Line turned over to be CCTV'ed	113306
11	9/14/2010	1610 N. Chapel Street	21213	Rags, Trash & Grease	Inner Harbor	0:55	1:05 PM - 2:00 PM	Gray Colored Water	550	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113391
12	9/16/2010	260 Deepdene Road	21210	Rags & Roots	Jones Falls	1:00	10:30 AM - 11:30 AM	Heavy Gray Water	120	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113482
13	9/19/2010	3337 Winterbourne Road	21216	Rags & Grease	Gwynns Falls	1:00	10:42 AM - 11:42 AM	Heavy Gray Water	120	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113572
14	9/20/2010	3700 Greenspring Ave	21211	Rags, Grease & Debris	Jones Falls	1:35	3:40 PM - 5:15 PM	Sewer Water, Feces, Grease, Paper Debris	950	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113610
15	9/23/2010	5300 Greenspring Ave	21209	Rags & Roots	Jones Falls	3:02	12:58 PM - 4:00 PM	Heavy Gray Water	910	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113747
16	9/24/2010	229 N Calhoun Street	21223	Rags & Grease	Gwynns Falls	1:00	9:10 AM - 10:10 AM	Heavy Gray Water	120	Cleaned Line with Electric Cutting Machine	Line turned over to be CCTV'ed	113770
17	9/28/2010	3203 Frisby Street	21218	Trash & Grease	Inner Harbor	2:05	7:55 AM - 10:00 AM	Gray Colored Water	125	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113868
18	9/30/2010	401 E Eager Street	21218	Heavy Rain	Inner Harbor	19:30	9/30/10 8:30 AM - 4:00 AM 10/1/10	Gray Colored Water	58,500	Wait for Heavy Rain to subside, limited hydraulic capacity	Line turned over to be CCTV'ed	113981
19	9/30/2010	1515 N Charles Street	21201	Heavy Rain	Jones Falls	19:30	9/30/10 8:30 AM - 4:00 AM 10/1/10	Heavy Gray Water	585,000	Wait for Heavy Rain to subside, limited hydraulic capacity	Wait for Line To Clear	113983
20	9/30/2010	1800 Falls Road	21202	Heavy Rain	Jones Falls	17:00	9/30/10 11:00 AM - 4:00 AM 10/1/10	Gray-Brown Colored Water	51,000	Wait for Heavy Rain to subside, limited hydraulic capacity	Will Check Periodically	113965
21	9/30/2010	4302 Parkton Street	21229	Heavy Rain & Grease	Patapsco	0:40	1:00 PM - 1:40 PM	Grey Colored Water	200	Relieved M/L Choke with Pressure Truck	Line turned over to be CCTV'ed	113971
22	9/30/2010	Durham @ Eager Street	21213	Heavy Rain	Inner Harbor	16:30	9/30/10 12:00 PM - 4:30 AM 10/1/10	Gray Colored Water	49,500	Wait for Heavy Rain to subside, limited hydraulic capacity	Line turned over to be CCTV'ed	113982
								TOTAL	749,627			